



中国国家强制性产品认证证书



证书编号: 2020322307002885

认证委托人名称: PMV Automation AB
认证委托人地址: Korta gatan 9, SE-171 54 Solna, Sweden
生产者名称: PMV Automation AB
生产者地址: Korta gatan 9, SE-171 54 Solna, Sweden
生产企业名称: Väsby Finmekanik AB
生产企业地址: Mellangården 6A, 194 51 Upplands Väsby; Sweden

产品名称: 数字式阀门定位器
系列、规格、型号: D30 系列, D20 系列
标准: GB 3836.1-2010、GB 3836.4-2010

上述产品符合强制性产品认证实施规则 CNCA-C23-01:2019 的要求, 特发此证。

发证日期: 2020 年 11 月 20 日 有效期至: 2025 年 10 月 15 日
首次发证日期: 2020 年 10 月 16 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批准:



上海仪器仪表自控系统检验测试所有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2020322307002885

APPLICANT: PMV Automation AB
ADDRESS: Korta gatan 9, SE-171 54 Solna, Sweden
MANUFACTURER: PMV Automation AB
ADDRESS: Korta gatan 9, SE-171 54 Solna, Sweden
FACTORY: Väsby Finmekanik AB
ADDRESS: Mellangården 6A, 194 51 Upplands Väsby; Sweden

PRODUCTNAME: Digital Valve Positioner
SERIES,SPECIFICATION,MODEL: D30 Series, D20 Series
STANDARDS: GB 3836.1-2010、GB 3836.4-2010

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

Valid from: November 20, 2020

Valid until: October 15, 2025

Date of original certification: October 16, 2020

The validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate is available through CNCA's website: www.cnca.gov.cn



APPROVAL:

Guo AiHua



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

<http://www.sitias.com.cn>

Building 9, 103 Cao Bao Road, Shanghai 200233, China

Tel: +86 21 64510844

S 0004045



中国国家强制性产品认证证书



SITIAS
Worldwide Access

证书编号: 2020322307002885

附 件

产品名称: 数字式阀门定位器

型号规格: D a b c d e f-g h-I j k l m n

a: 20, 21, 22, 30, 31, 33;

b: N;

c: S, H;

d: G, M, N;

e: 2, 4, T, F;

f: 与防爆性能无关;

g: 与防爆性能无关;

h: 与防爆性能无关;

i: 与防爆性能无关;

j: 4, 5, P, F;

k: X, T, 5, 6, 7, 8, G, N, P, S, U;

l: 0, 3, 2;

m: 与防爆性能无关;

n: 与防爆性能无关。

防爆标志: Ex ia IIC T4 Ga

批 准:



上海仪器仪表自控系统检验测试所有限公司



中国国家强制性产品认证证书



SITIAS
Worldwide Access

证书编号: 2020322307002885

附 件

电气参数:

回路	U_i (V)	I_i (mA)	P_i (mW)	L_i (μH)	C_i (nF)
PA, FF, FISCO (1, 2, 3, 4)	17.5	380	5320	10	5
4~20mA输入 (1, 2)	28	93	653	11.3	11.3
4~20mA输出 (3, 4)	28	93	653	11.3	22
开关 (5, 6, 7, 8, 9, 10) Dabcde-fghi-jkGmno Dabcde-fghi-jkSmno Dabcde-fghi-jkPmno	28	45	315	1	1
开关 (5, 6, 7, 8, 9, 10) Dabcde-fghi-jkNmno	16	25	34	50	40
开关 (5, 6, 7, 8, 9, 10) Dabcde-fghi-jkUmno	16	25	34	100	100
开关 (5, 6, 7, 8, 9, 10) Dabcde-fghi-jk5mno Dabcde-fghi-jk6mno	16	25	34	100	30
开关 (5, 6, 7, 8, 9, 10) Dabcde-fghi-jk7mno Dabcde-fghi-jk8mno	16	25	34	150	150

批 准:



上海仪器仪表自控系统检验测试所有限公司