



FM Approvals
1151 Boston Providence Turnpike
P.O. Box 9102 Norwood, MA 02062 USA
T: 781 762 4300 F: 781-762-9375 www.fmapprovals.com

Member of the FM Global Group

CERTIFICATE OF COMPLIANCE

HAZARDOUS (CLASSIFIED) LOCATION ELECTRICAL EQUIPMENT

This certificate is issued for the following equipment:

PT 32-abc-d, Pressure Transmitters.

XP/II/1/BCD/T6 Ta=65°C; DIP/II,III/1/EFG/T6 Ta=65°C; Type 4X/IP66.

a = Housing color: W, Y, B, S

b = Threaded connections: 1, 2, 3, 4

c = O-ring material: Z, Q, V

d = Mounting Options: N, P

Equipment Ratings:

Explosionproof for use in Class I, Division 1, Groups B, C and D; and Dust-Ignitionproof for Class II/III, Division 1, Groups E, F and G; hazardous (classified) locations, indoor and outdoor (Type 4X/IP66).

FM Approved for:

Palmstierna International AB
Korta Gatan 9
SE-171 54 Solna
Sweden



This certifies that the equipment described has been found to comply with the following Approval Standards and other documents:

Class 3600	1998
Class 3615	2006
Class 3810	2005
ANSI/IEC 60529	2004
ANSI/NEMA 250	1991


Original Project ID: 3032413

Approval Granted: *August 31, 2009*

Subsequent Revision Reports / Date Approval Amended

Report Number	Date	Report Number	Date
---------------	------	---------------	------

FM Approvals LLC



J. E. Marquardt
Group Manager, Electrical

31 August 2009

Date