



Certificate of Compliance

Certificate: 1278854

Master Contract: 176847

Project: 80011256

Date Issued: 2019-10-30

Issued To: Flowserve/PMV Automation AB
Korta Gatan 9
Solna, ., 171 54
Sweden

Attention: Mats Ragnarsson

The products listed below are eligible to bear the CSA Mark shown

Issued by: *Joe DaSilva*
Joe DaSilva



PRODUCTS

CLASS - C225802 - PROCESS CONTROL EQUIPMENT For Hazardous Locations

Class I, Division 1, Groups C and D; Class II, Division 1, Groups E, F and G; Class III, Division 1; Encl. Type 4X:

Model D3E Series Electronic-Pneumatic Valve Positioner; input rated 28V dc, 24 mA max; Temp. Code T6 @ Max Ambient 65 Deg C; Temp. Code T5 @ Max Ambient 80 Deg C. Minimum ambient temperature -40 Deg C.



Certificate: 1278854
Project: 80011256

Master Contract: 176847
Date Issued: 2019-10-30

APPLICABLE REQUIREMENTS

CAN/CSA Standard C22.2 No. 0-M91
(Reaffirmed 2014)

CSA Standard C22.2 No. 25-1966
(Reaffirmed 2004)

CSA Standard C22.2 No. 30-M1986
(Reaffirmed 2016)

CAN/CSA-C22.2 No. 94-M91
(Reaffirmed 2006)

CSA Standard C22.2 No. 142-M1987
(Reaffirmed 2004)

General Requirements - Canadian Electrical Code, Part II

Enclosures for Use in Class II, Groups E, F and G
Hazardous Locations

Explosion-Proof Enclosures for Use in Class I Hazardous
Locations

Special Purpose Enclosures

Process Control Equipment



Supplement to Certificate of Compliance

Certificate: 1278854

Master Contract: 176847

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
80011256	2019-10-30	Evaluation of new flame arrestor used with valve positioner
000070025907	2016-01-14	update report 1278854 to include the -40#C min
0002317509	2010-06-18	Update to Report 1278854 to include several drawing revision updates.
0002208387	2010-01-21	Update to Report 1278854 to include alternate stainless steel enclosure.
0002010838	2008-05-08	Update Rpt.1278854 to include CSA dhesive label material for marking plate Zebra Z-Extreme 4000 Silver
0001944668	2007-12-06	Revised Construction of DE3 Electro-pneumatic Positioner