



中国国家强制性产品认证证书



证书编号: 2020322304003449

认证委托人名称: PMV Automation AB

认证委托人地址: Korta gatan 9, SE-171 54 Solna, Sweden

生产者名称: PMV Automation AB

生产者地址: Korta gatan 9, SE-171 54 Solna, Sweden

生产企业名称: ProvideU Assembly OU

生产企业地址: LAKI 12b 10621 Tallinn Estonia

产品名称: 阀位指示器

系列、规格、型号: DS a b c d e f g h i j k l, DM a b c d e f g h i j k l

标 准: GB 3836.1-2010、GB 3836.2-2010、GB 12476.1-2013、
GB 12476.5-2013

上述产品符合强制性产品认证实施规则 CNCA-C23-01:2019 的要求, 特发此证。

发证日期: 2020 年 12 月 3 日

有效期至: 2025 年 12 月 2 日

首次发证日期: 2020 年 12 月 3 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批 准:



上海仪器仪表自控系统检验测试所有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2020322304003449

APPLICANT: Korta gatan 9, SE-171 54 Solna, Sweden

ADDRESS: Korta gatan 9, SE-171 54 Solna, Sweden

MANUFACTURER: Korta gatan 9, SE-171 54 Solna, Sweden

ADDRESS: Korta gatan 9, SE-171 54 Solna, Sweden

FACTORY: ProvideU Assembly OU

ADDRESS: LAKI 12b 10621 Tallinn Estonia

PRODUCTNAME: Ultraswitch

SERIES,SPECIFICATION,MODEL: DS a b c d e f g h i j k l, DM a b c d e f g h i j k l

STANDARDS: GB 3836.1-2010、GB 3836.2-2010、GB 12476.1-2013、
GB 12476.5-2013

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

Valid from: December 3, 2020

Valid until: December 2, 2025

Date of original certification: December 3, 2020

The validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate is available through CNCA's website: www.cnca.gov.cn



APPROVAL:

Guo AiHua



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

<http://www.sitilas.com.cn>

Building 9, 103 Cao Bao Road, Shanghai 200233, China

Tel: +86 21 64510844

S 0004201



中国国家强制性产品认证证书



SITIAS
Worldwide Access

证书编号: 2020322304003449

附 件

产品名称: 阀位指示器

型号规格: DS a b c d e f g h i j k l

a: 1, 2, 3

b: S, 或其他任意值

c: 与防爆无关代码

d: 与防爆无关代码

e: 0, 1, 2, 3, 4

f: M1, MC, MG, MK, P4, P5, PE, PP, PT, N1, N3, N8, N9, NA, NC, ND, NE, NF, NG, NK, NM, NP,

NQ, NR, NS, NT, NW, NY, F3, FC, F5, F6, F7, F8

g: 38

h: 0, M

i: 0, 4, R

j: 0, 2, 4, 6

k: 0, V

l: 与防爆无关代码

DM a b c d e f g h i j k l

a: 1, 2, 3

b: S, 或其他任意值

c: 与防爆无关代码

d: 与防爆无关代码

e: 0, 1, 2, 3, 4

f: M1, MC, MG, MK, P4, P5, PE, PP, PT, N1, N3, N8, N9, NA, NC, ND, NE, NF, NG, NK, NM, NP,

NQ, NR, NS, NT, NW, NY, F3, FC, F5, F6, F7, F8

批 准:



上海仪器仪表自控系统检验测试所有限公司



中国国家强制性产品认证证书



证书编号: 2020322304003449

附 件

g:38
h:0, M
i:0, 4, R
j:0, 2, 4, 6
k:0, V
l:与防爆无关代码

防爆标志: Ex d IIC T5 Gb, Ex tD A21 IP66 T94℃

电气参数: 最大额定电压为250V, 最大额定电流为10A

批 准:



上海仪器仪表自控系统检验测试所有限公司