



中国国家强制性产品认证证书



证书编号: 2020322304003491

认证委托人名称: PMV Automation AB

认证委托人地址: Korta gatan 9, SE-171 54 Solna, Sweden

生产者名称: PMV Automation AB

生产者地址: Korta gatan 9, SE-171 54 Solna, Sweden

生产企业名称: ProvideU Assembly OU

生产企业地址: LAKI 12b 10621 Tallinn Estonia

产品名称: 阀位指示器

系列、规格、型号: DS a b c d e f g h i j k l, DM a b c d e f g h i j k l

标 准: GB 3836.1-2010、GB 3836.4-2010、GB 12476.1-2013、
GB 12476.4-2010

上述产品符合强制性产品认证实施规则 CNCA-C23-01:2019 的要求, 特发此证。

发证日期: 2020 年 12 月 11 日

有效期至: 2025 年 12 月 10 日

首次发证日期: 2020 年 12 月 11 日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。

本证书的相关信息可通过国家认监委网站 www.cnca.gov.cn 查询



批 准:



上海仪器仪表自控系统检验测试所有限公司



CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION



CERTIFICATE NO: 2020322304003491

APPLICANT: PMV Automation AB
ADDRESS: Korta gatan 9, SE-171 54 Solna, Sweden
MANUFACTURER: PMV Automation AB
ADDRESS: Korta gatan 9, SE-171 54 Solna, Sweden
FACTORY: ProvideU Assembly OU
ADDRESS: LAKI 12b 10621 Tallinn Estonia

PRODUCTNAME: Ultraswitch
SERIES,SPECIFICATION,MODEL: DS a b c d e f g h i j k l, DM a b c d e f g h i j k l
STANDARDS: GB 3836.1-2010、GB 3836.4-2010、GB 12476.1-2013、
GB 12476.4-2010

This is to certify that the above mentioned product(s) complies with the requirements of implementation rules for compulsory certification (REFNO. CNCA-C23-01:2019).

Valid from: December 11, 2020

Valid until: December 10, 2025

Date of original certification: December 11, 2020

The validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

This certificate is available through CNCA's website: www.cnca.gov.cn



APPROVAL:

Guo AiHua



Shanghai Inspection and Testing Institute of Instruments and Automation Systems Co., Ltd.

<http://www.sitiias.com.cn>

Building 9, 103 Cao Bao Road, Shanghai 200233, China

Tel: +86 21 64510844

S 0004234



中国国家强制性产品认证证书



证书编号: 2020322304003491

附 件

产品名称: 阀位指示器

型号规格: DS a b c d e f g h i j k l

a: 1, 2, 3

b: S, 或其他任意值

c: 与防爆无关代码

d: 与防爆无关代码

e: 0, 1, 2, 3, 4

f: M1, MG, MK, P4, P5, PE, PT, N3, N8, NC, NE, NF, NM, NP, NW, NY

g: 43

h: 0, M

i: 0, R

j: 0, 2, 4, 6

k: 0, V

l: 与防爆无关代码

DM a b c d e f g h i j k l

a: 1, 2, 3

b: S, 或其他任意值

c: 与防爆无关代码

d: 与防爆无关代码

e: 0, 1, 2, 3, 4

f: M1, MG, MK, P4, P5, PE, PT, N3, N8, NC, NE, NF, NM, NP, NW, NY

g: 43

h: 0, M

批 准:



上海仪器仪表自控系统检验测试所有限公司



中国国家强制性产品认证证书



证书编号: 2020322304003491

附 件

i:0, R
j:0, 2, 4, 6
k:0, V
l:与防爆无关代码

防爆标志: Ex ia IIC T4 Ga, Ex iaD 20 T135°C

电气参数:

型号	U _i (V)	I _i (mA)	P _i (mW)	L _i (μH)	C _i (nF)	T4	T135°C
DMabcde M1ghijkl DSabcde M1ghijkl	28	45	315	1	1	(-40~+78) °C	(-40~+85) °C
DMabcde MGghijkl DSabcde MGghijkl	28	45	315	1	1	(-40~+78) °C	(-40~+85) °C
DMabcde MKghijkl DSabcde MKghijkl	28	45	315	1	1	(-55~+78) °C	(-55~+85) °C
DMabcde N3ghijkl DSabcde N3ghijkl	16	52	169	100	30	(-25~+68) °C	(-25~+89) °C
DMabcde N8ghijkl DSabcde N8ghijkl	16	52	169	50	40	(-25~+68) °C	(-25~+89) °C
DMabcde NCghijkl DSabcde NCghijkl	16	52	169	50	45	(-25~+67) °C	(-25~+67) °C
DMabcde NEghijkl DSabcde NEghijkl	16	52	169	100	90	(-25~+81) °C	(-25~+81) °C
DMabcde NFghijkl DSabcde NFghijkl	16	52	169	100	95	(-25~+81) °C	(-25~+81) °C

批 准:



上海仪器仪表自控系统检验测试所有限公司



中国国家强制性产品认证证书



证书编号: 2020322304003491

附 件

DMabcde NMghijkl DSabcde NMghijkl	16	52	169	150	50	(-40~+80)℃	(-40~+81)℃
DMabcde NPghijkl DSabcde NPghijkl	16	52	169	250	50	(-25~+68)℃	(-25~+89)℃
DMabcde NWghijkl DSabcde NWghijkl	16	52	169	100	30	(-40~+68)℃	(-40~+89)℃
DMabcde NYghijkl DSabcde NYghijkl	16	52	169	150	70	(-50~+74)℃	(-50~+80)℃
DMabcde P4ghijkl DSabcde P4ghijkl	28	45	315	1	1	(-10~+40)℃	(-10~+85)℃
DMabcde P5ghijkl DSabcde P5ghijkl	28	45	315	1	1	(-40~+80)℃	(-40~+85)℃
DMabcde PEghijkl DSabcde PEghijkl	28	45	315	1	1	(-40~+80)℃	(-40~+85)℃
DMabcde PTghijkl DSabcde PTghijkl	28	45	315	1	1	(-40~+80)℃	(-40~+85)℃

批 准:



上海仪器仪表自控系统检验测试所有限公司