

Rev 21

F5 feedback unit order code

A= Model No

F 5 Feedback unit, to be installed on top of P5/EP5, no cover incl.

F5

B= Electrical connection

G 2 x M20 x 1,5

N 2 x 1/2" NPT

C= Surface treatment

U Epoxy, ED

M Tuftram (B=N only)

D= Switches

M E C 2 x SPDT switches

N A M 2 X Namur sensors

P X Y 2 x SPDT proximty switches

S A P 2 x (P+F NBB2-V3-E2). (Sappi Version, only when E= XXX)

E= Feedback

X X X None

P O T Potentiometer, 5 kOhm

P 1 K Potentiometer, 1 kOhm

P 1 8 Potentiometer, 180 deg

P 2 7 Potentiometer 270 deg

4 2 0 4-20 mA transmitter

T 1 8 4-20 mA transmitter, 180deg

T 2 7 4-20 mA transmitter, 270 deg

F= Spindle

0 0 For installation on P5/EP5, no other spindle available.

G= Temperature

Z Nitrile, NBR -40 to +85 deg C

- - -