

EU DECLARATION OF CONFORMITY

We the manufacturer: **Palmstierna International** and **PMV Automation AB, Korta Gatan 9, SE-171 54 Solna**, under sole responsibility declare that the product,

Range of Rotary Switch On/Off Valve Indicators (XCL)

is in conformity with the following harmonised legislation:

Directive: **2014/30/EU (EMC)**

Applied Standards: **EN 61000-6-2, 3 and 4**

Directive: **2014/35/EU (Low Voltage Directory)**

Applied Standards: **EN 60204-1**

Directive: **2014/34/EU (ATEX)**

Applied Standards: **EN 60079-0:2004** (EN IEC 60079-0:2018)*

EN 60079-1:2004 (EN 60079-1:2014)*

EN 61241-0:2006 (EN IEC 60079-0:2018)*

EN 61241-1:2004 (EN 60079-31:2014)*

** A review between standards used during certification and the harmonized standards (in parenthesis) have identified no significant change relevant for the construction and commissioning of this product.*

Quality Assurance: **Nemko, P.O.Box 73 Blindern, N-0314 Oslo, Norway**

Notified body Certificate: **Sira Certification Service, Rake Lane, Eccleston, Chester; CH4 9JN, England.**

Moved to: **CSA Group Netherlands B.V., Utrechseweg 310, 6812 AR, Arnhem, Netherlands (following Brexit)**


Product marking :



II 2 GD

Ex d IIB T5

Ex tD A21 IP66/67 (Ta-20°C to +55°C)



Authorized Person for the manufacturer

EU-type examination
Certificate

Sira 06ATEX3392X

Model code (x=any character)

xxXxLxxxx-18-xxxxx

xxXxLxxxx-19-xxxxx

xxXxLxxxx-M3-xxxxx

DxAxxx1x(xxxxxx)

DxAxxx3x(xxxxxx)

Mikael Ekman
Site Manager
Solna, Sweden